

Sample Name :

Heavy Hydrocarbon

| Test              | Unite             | Test method              | Guaranty Range | Result    |
|-------------------|-------------------|--------------------------|----------------|-----------|
| DISTALION         | ·C<br><br>VOL%    | ASTM D 86                | -              | DISTALION |
| IBP               |                   |                          |                | 153       |
| 5%                |                   |                          |                | 160       |
| 10%               |                   |                          |                | 170       |
| 20%               |                   |                          |                | 182       |
| 30%               |                   |                          |                | 196       |
| 40%               |                   |                          |                | 209       |
| 50%               |                   |                          |                | 221       |
| 60%               |                   |                          |                | 236       |
| 70%               |                   |                          |                | 252       |
| 80%               |                   |                          |                | 275       |
| 90%               |                   |                          |                | 306       |
| 95%               |                   |                          |                | 320       |
| FBP               |                   |                          |                | 348       |
| RESIDUE           |                   |                          |                | 0.8       |
| LOSS              | 0.2               |                          |                |           |
| Density(15c)      | g/cm <sup>3</sup> | ASTM D1298               | -              | 0.808     |
| Pour Point        | -                 | ASTM D97                 | -              | -         |
| Appear & Color    | -                 | ASTM D1500<br>ASTM D2932 | -              | 1.5       |
| Total Sulfur      | ppm               | ASTM4294                 | -              | 4000      |
| Flash Point       | ·C                | ASTM D92<br>ASTM D93     | -              | 51        |
| Viscosity(15.56c) | c.st              | ASTM D445                | -              | -         |
| RON               | -                 | ERALYTICS<br>Eraspec     | -              | -         |
| MON               | -                 | ERALYTICS<br>Eraspec     | -              | -         |
| AKI               | -                 | ERALYTICS<br>Eraspec     | -              | -         |
| ETH               | -                 | ERALYTICS<br>Eraspec     | -              | -         |
| Tolerance         | -                 | -                        | -              | ±10       |

 Web site: [www.eskavir.com](http://www.eskavir.com)

 Email : [info@eskavir.com](mailto:info@eskavir.com)

Tel: 035-37275038